

RESIDENTIAL CONNECTIONS

Pipe shall be four (4) inches in diameter with a minimum wall thickness of SDR 35; SDR 21 is recommended. Pipe shall be installed with a fall of approximately twelve (12) inches per one hundred (100) feet. Pipe shall be back-filled underneath to maintain proper grade.

There shall be no ninety (90) degree elbows used in the pipeline. If a bend is needed, the usage of two (2) forty-five (45) degree elbows is required with a clean-out before and after the bend.

Clean-outs shall be installed beginning at the house with one (1) clean-out every fifty (50) feet thereafter. There shall be a clean-out located prior to entry into the city sewer line or any lateral line. All clean-outs shall be four (4) inches in diameter with a height of ground level or above.

PIPE INSTALLATION SHALL NOT BE COVERED BEFORE INSPECTION AND APPROVAL BY A REPRESENTATIVE OF THE GORDONSVILLE SEWER DEPARTMENT.

Inspection requests must be made one (1) working day prior to inspection. No inspections shall be made before or after business hours, on weekends, holidays or during bad weather conditions.

For additional information or to make an appointment for an inspection, call Drew Gentry, Gordonsville Wastewater Treatment Plant at 615-735-0109.

Drew Gentry
Waste Water Plant Manager

Office: 615-735-0109

Fax: 615-683-5656

Email: gordsewer@dtccom.net